



Product Manual

CONTINUOUS LEVEL CONTROLS

7250 Series HR Digital Stik



**ABSOLUTE PROCESS CONTROL
KNOW WHERE YOU ARE... REGARDLESS**



AMETEK®
AUTOMATION & PROCESS TECHNOLOGIES

7250 Series Manual

Overview

This document explains the basic hardware interface requirements, operating characteristics and describes the software protocols for the 7250 series HR Digital Stik. In addition, the dimension and installation drawings, part number sequence and agency approvals have been included in the back of this document. It is important to note that the standard product is intrinsically safe and any device, controller, or radio connected to this product must have a barrier designed to meet the entity parameters and special requirements indicated in the installation drawing E0241200 (page 6).

Electrical Interface

Signal Descriptions

The 7250 requires only three wires for its power and interface connections, Power, Data, and Ground. On the Stainless Steel housing models, the cable shield or "Shield" pin in the 4 pin connector, is connected to the steel housing and must be connected to earth ground.

Power Supply

The supply voltage to the probe "Power" is typically +5VDC but can range from 3.7VDC to 7.93VDC. The main power supply in the 7250 is not a "switching" design, so running it at a higher voltage does not reduce the input current draw.

Data Signal

The "Data" signal is an "open-drain" type signal and is used for the bidirectional half duplex asynchronous serial communications. Any device connected to the probe must be of an "open-drain" type signal and must not be driven to a high logic level. Because this data signal may be driven by either the master or any slave device, a single pull up resistor of typically $1k\Omega$ should be the only element that establishes the high logic level voltage. Also, because of this scheme, there could be multiple master or slave devices connected together.

The logic level voltage thresholds are similar to TTL levels and a pull-up resistor must be included in the user's interface circuitry. This signal is clamped internally by the 7250 with a +5V TVS

device. The inactive or "idle" state is at a "high" logic level.

Ground

The "Ground" connection is the common return path for both "power" and "data".

Intrinsically Safe Connections

The 7250 is an intrinsically safe device and therefore, when used in an intrinsically safe installation or application, must be connected to an apparatus that limits the power, voltage, and current to the 7250 in accordance to the entity parameters specified. Reference the installation drawing E0241200 (page 6) for more details.

Operation

The 7250 runs continuously once power is applied to it. When connected to a battery powered device (typically a wireless radio), power is supplied for a short duration of time, long enough to collect the required amount of data, then power is switched off to the probe in an effort to reduce the power draw and conserve battery life. If power is applied to the 7250 on a continuous basis, it will continue to take level and temperature readings and communicate the data through the asynchronous serial communications signal.

Power Consumption

The 7250 draws roughly 10mA of current when it is not taking temperature measurements and roughly 12mA of current when it is taking temperature measurements (with 5 temperature sensors). Figure 1 shows the current draw of a model 7252 which takes the temperature readings in the beginning (approximately 700mS) and also takes 25 product and 1 interface (water) reading at 100mS per reading. As seen in the chart, this is represented by the 700mS high level followed by the 2 second lower reading. The signal in the screen capture is a voltage reading taken across a 10 ohm resistor in series with the power supply input. The scale for this reading is 1mA per minor division and 5mA per major division.

Software Protocol

There are several different product numbers available for the 7250 Series of probes. The 'x' in the part number 725x identifies the data protocol. The electrical interface remains the same, regardless of the software protocol specified by the model number.

There are currently two different software protocol versions available (7252 and 7255). In actuality, the 'protocols' are very similar. The significant difference is the amount of product measurements transmitted within the data string. A unique start character is also sent at the beginning of each data string to identify the data string type, or hence, the 'protocol'.

Communication Parameters (fixed)

baud	9600
parity	odd
data bits	7
start bits	1
stop bits	1

Data Format

The data string is in **ASCII** format and the total data string transmission time is roughly one (1) second for the 7255 and three (3) seconds for the 7252.

Approximately 100ms after power up, a start character ("=" for 7252, "<" for 7255) is transmitted and the first product position is measured and transmitted. Subsequent position measurements and transmissions continue every 100ms until the complete number of products has been transmitted. One interface position is transmitted immediately following the final product position. All temperature data is then transmitted along with a final 2-digit ASCII Checksum followed by a Carriage Return character to end the string. Note that a comma character (',') is transmitted between each position and temperature measurement (see example below).

The probe will continue to take level and temperature readings and the data string transmission process continues repeatedly as long as power is applied to the probe.

The data string length is protocol dependent (i.e. 269 bytes for 7252; 134 bytes for 7255). The data string is comprised of a start character, product levels (protocol dependent: 25 for 7252; 10 for 7255), 1 interface level, and 5 temperature sensor levels followed by a 2-digit ASCII Checksum and a carriage return character (<CR>).




Fig. 1 Power Consumption

For probes ordered with only 1 temperature sensor (i.e. T1 or R1), the temperature reading value of that one sensor is placed in all five temperature data locations in the string.

NOTE: Data values outside the ranges specified above indicate an error condition.

Data String	
s,ppp.pppp,ppp.pppp,... ...,ppp.pppp,iii.iii,+/tt.t,...,+/-tt.t,CC<cr>	
s:	Start Character (identifies protocol, type and quantity of following data)
ppp.pppp:	Product (000.0000" to 600.0000")
iii.iii:	Interface (000.0000" to 600.0000") (Note: Interface = 000.0000 if Stik is ordered with only 1 float)
+/-tt.t:	Temperature (-40.0°C to +85.0°C)
CC:	2 digit ASCII checksum (see calculation process below)
<CR>:	End of data string - carriage return

A value of "999.9999" will be transmitted if there is an error in the product or interface levels.

A value of "-99.9" will be transmitted if there is an error in the temperature sensor level.

Calculation of Checksum:

All the ASCII characters (from and including the start character to and including the comma (',') after the final temperature digit) in the data string are added together. From this number, the least significant byte is used for the checksum value and is transmitted in its equivalent ASCII characters. Note that capital letters MUST be used for the upper hex values (i.e. 'A', 'B', 'C', 'D', 'E', 'F').

For example:

If the checksum value was 0xA5 (hex); An ASCII 'A' and a '5' characters would be transmitted to indicate the checksum value (i.e. 0x41 and 0x35.....the ASCII characters for 'A' and '5').

Data Transmission Example

The following example represents the data transmitted from a 7255 HR Digital Stik (i.e. 10 product levels) which has a full transmission data string length of 134 bytes. Bytes 0 – 130 are used to compute the checksum:

NOTE: The Level values used in the following chart may not be representative of a real life application. The data provided is for example purposes only.

Byte #s	ASCII Chr String	Level Name
0-1	<,	Start Character
2-10	123.4567,	Product 1
11-19	456.7890,	Product 2
20-28	654.3212,	Product 3
29-37	987.6543,	Product 4
38-46	124.5789,	Product 5
47-55	234.5678,	Product 6
56-64	267.4310,	Product 7
65-73	478.2354,	Product 8
74-82	752.6143,	Product 9
83-91	891.4578,	Product 10
92-100	002.5389,	Interface 1
101-106	+22.1,	Temperature 1
107-112	+22.3,	Temperature 2
113-118	+22.5,	Temperature 3
119-124	+22.3,	Temperature 4
125-130	+22.1,	Temperature 5
131-132	CC	2-digit ASCII Checksum
133	<cr>	Carriage Return

NOTE: To determine the actual location of a temperature sensor, refer to the Thermometer Spacing tables on Drawing D0246600, sheet 2 of 2, included on page 9 of this manual.




Fig. 2 Temperature Sensor Location and Spacing for the 7250X Series

Installation of PVDF Probe**CAUTION** **NOTE: Special Conditions for Safe Use**

The equipment contains non-metallic enclosure parts, to prevent the risk of electrostatic sparking the non-metallic surface should only be cleaned with a damp cloth.

Installation**IMPORTANT**

Be sure to read & understand all of the Instructions before beginning.

It is recommended that a minimum of a 2" NPT pipe opening be used.

Unpacking

Carefully remove the contents of the shipping carton and check each item against the packing list before destroying any packing materials.

Storage

Level gauge probes should be stored in their original shipping containers until ready for installation.



Damage that occurs in storage is not covered under manufacturer warranty.

Mounting Conditions**CAUTION**

- When installing probes, do not bend rigid probes, permanent damage may result.
- Longer rigid probes need to be supported at both ends while handling.
- Probes are sealed at the factory and contain no user serviceable components.
- Do not attempt to open probe or weld the tube.
- Level gauge probes are designed for industrial applications, but should be mounted in a location as free as possible from vibration, corrosive atmospheres, or any possibility of mechanical damage.
- Place the level gauge in a reasonably accessible location, ambient temperature should be between -40°F and 158°F (-40°C to 70°C).
- Mount the Level gauge probe perpendicular with gravity.
- Float should have free movement along probe.
- Float retention clip should be in place at base of probe.

Mounting Considerations

Mounting considerations may vary (Flanges, Compression Fitting, etc.) depending on the application. For underground tanks, the probe is generally mounted in the riser, resting on the bottom of the tank. Spacers are used to hold the sensor in the center of the riser. While most underground tanks are horizontal and fairly standard in design, above ground tanks vary considerably. The requirements for mounting these probes are fairly simple. Since the probe requires a float to provide level position, there is a minimum size required for insertion of the float into the tank.



7250 Series Specifications


Specifications			
Indicated Level up to one product reading and one interface reading		Logic Levels	V_{OH} 2.7v (Leakage current is less than 1µA) V_{OL} 0.4v (5mA load) V_{IH} 2.1v V_{IL} 0.9v
316 Stainless Steel Resolution ¹ Repeatability Linearity Hysteresis	Lengths up to 288" 0.0001" Equal to Resolution +/- 0.01% ² +/- 0.002% ³		
PVDF (Rigid) Resolution ¹ Repeatability Linearity Hysteresis	Lengths up to 192" 0.0001" Equal to Resolution +/- 0.01% ² +/- 0.002% ³	Cable The cable will be a shielded 3 conductor 22AWG with a PVC jacket (Belden 6501FE or equivalent)	Red Power White Data Signal Black Common Drain Cable shield, Chassis ground on S.S. housing probes
PVDF (Flexible) Resolution ¹ Repeatability Linearity Hysteresis	Lengths from 193" up to 840" 0.0001" Equal to Resolution +/- 0.01% ⁴ +/- 0.002% ³		
Indicated Temperature up to 5 temperature sensors		Data Update Time ¹ Position data Temperature data	0.100 seconds 0.800 seconds
Resolution Repeatability Accuracy 0°C to +100°C -40°C to -1°C & +101°C to +125°C	0.1°C +/- 0.3°C +/- 0.75°C +/- 1.0°C		
Power Supply Voltage Current (@+5VDC)	+5 VDC, +/- 10 % typical (+3.7VDC Minimum) 10mA max. (8mA typical) plus 1.5mA max (1mA typical) per temperature sensor	Intrinsically Safe Entity Parameters	V_{max} 7.93 V I_{max} 280 mA P_i 1.0 W C_i 30.1 uF L_i 0 µH
Operating Temperature: -40°C to 70°C (Consult Factory for Higher Temperatures)			
Specifications are subject to change without notice. Patented.			

¹ protocol dependent² or +/- 0.015", whichever is greater³ or +/- 0.005", whichever is greater⁴ or +/- 0.039", whichever is greater

Hazardous Areas Approvals	Sanitary Approvals
FM  -40° ≤ Tamb ≤ 70° C Class I, II, III, Div. 1 Groups C, D, E, F, G, T4 Class I, Div. 2 Groups A, B, C, D, T4 Class I, Zone 0, AEx/Ex ia IIB T4	ATEX Ex ia IIB T4 Ga FM13ATEX0102X IECEx FMG 12.0008X Issued Date: 06/29/12 IEC 60079-0:2011 IEC 60079-11:2011 IEC 60079-26:2006 INMETRO IEE 12.0046X (See PVDF installation note)  0575 

7250 Series Part Numbering Sequence


7250 Series Part Numbering




7250 Installation Drawing

NON HAZARDOUS AREA		HAZARDOUS AREA																											
		<p>FM APPROVED</p> <p>GROUP IIC, ZONE 2 CLASS I, DIV 1, GROUPS C & D CLASS II & III, GROUPS E, F & G -- CLASS I, DIV 2, GROUPS A, B, C & D</p> <p>ATEX FMI 3ATEX0102X</p> <p>Ex II 1 G Ex ia T4 Ga Temp: -40°C to +70°C</p>																											
		<p>**APPROVED DOCUMENT ** CHANGES TO THIS DOCUMENT REQUIRE AGENCY APPROVAL</p> <p>REV. A ADDED NOTE 8 B CHANGED TITLE AND SERIES NAME C REVISED NOTE 8, CONDITIONS FOR SAFE USE</p> <p>DATE 07/18/05 06/01/11 12/12/13</p> <p>BY KTP JCP GSL</p> <p>NOTES: UNLESS OTHERWISE SPECIFIED</p> <ol style="list-style-type: none"> 1. MINIMUM VOLTAGE TO OPERATE THE 7250 PROBE IS 3.6V. 2. THE SELECTED BARRIER SHALL BE APPROVED WITH INTRINSICALLY SAFE CIRCUITS FOR THE HAZARDOUS LOCATION GROUP AND ZONE AS APPROPRIATE FOR THE APPLICATION AND INSTALLED IN ACCORDANCE WITH MANUFACTURER'S INSTALLATION INSTRUCTIONS. 3. ELECTRONIC EQUIPMENT CONNECTED TO THE ASSOCIATED APPARATUS MUST NOT USE OR GENERATE MORE THAN 250Vrms, WITH RESPECT TO EARTH GROUND. 4. INSTALLATIONS SHALL COMPLY WITH THE LATEST EDITION OF THE NATIONAL ELECTRICAL CODE (ANSI/NFPA 70) AND THE CANADIAN ELECTRICAL CODE (CEC). 5. ALL CABLES MUST BE 24 GAUGE OR HEAVIER. 6. INSTALLATIONS SHALL BE IN ACCORDANCE WITH ANSI/ASL RP 12.06.01, INSTALLATION OF INTRINSICALLY SAFE SYSTEMS FOR HAZARDOUS (CLASSIFIED) LOCATIONS. 7. FOR FM APPROVAL, THE ASSOCIATED APPARATUS MUST BE FM APPROVED. 8. SPECIAL CONDITIONS FOR SAFE USE: THE EQUIPMENT CONTAINS NON-METALLIC ENCLOSURE PARTS. TO PREVENT THE RISK OF ELECTROSTATIC SPARKING, THE NON-METALLIC SURFACE SHOULD ONLY BE CLEANED WITH A DAMP CLOTH. 																											
		<p>POWER (+) ZENER BARRIER PARAMETERS (1)</p> <table border="1"> <tr> <td>Voc(1)</td> <td>Voc(1) <= Vmax</td> </tr> <tr> <td>Isc(1)</td> <td>Isc(1) <= Imax-Isc(2)</td> </tr> <tr> <td>Ca(1)</td> <td>Ca(1) >= Ci+Lwire(1)+Cwire(2)</td> </tr> <tr> <td>Lo(1)</td> <td>Lo(1) >= [Li+Lwire(1)+Lwire(2)]-Lo(2)</td> </tr> </table> <p>DATA ZENER BARRIER PARAMETERS (2)</p> <table border="1"> <tr> <td>Voc(2)</td> <td>Voc(2) <= Vmax</td> </tr> <tr> <td>Isc(2)</td> <td>Isc(2) <= Imax-Isc(1)</td> </tr> <tr> <td>Ca(2)</td> <td>Ca(2) >= Ci+Cwire(2)+Cwire(1)</td> </tr> <tr> <td>Lo(2)</td> <td>Lo(2) >= [Li+Lwire(2)+Lwire(1)]-Lo(1)</td> </tr> </table> <p>POWER (+) ZENER BARRIER PARAMETERS (1)</p> <table border="1"> <tr> <td>Pi</td> <td>Vmax</td> <td>Imax</td> <td>Ci</td> <td>Li</td> </tr> <tr> <td>1W</td> <td>7.93V</td> <td>280mA</td> <td>30.1μF</td> <td>0μH</td> </tr> </table> <p>ENTITY PARAMETER NOTES:</p> <ol style="list-style-type: none"> 1. PARAMETERS APPLY COLLECTIVELY TO BOTH "POWER (+)" AND "DATA" TERMINALS WITH RESPECT TO "COMMON (-)". 2. Pi IS THE TOTAL (OR SUM) OF THE POWER APPLIED TO BOTH THE POWER (+) AND "DATA" TERMINALS. 3. Vmax IS THE MAXIMUM VOLTAGE THAT CAN BE APPLIED TO EITHER THE POWER (+) OR "DATA" TERMINALS. 4. Imax IS THE TOTAL (OR SUM) OF THE CURRENT APPLIED TO BOTH THE POWER (-) AND "DATA" TERMINALS. <p>IF WIRE PARAMETERS ARE UNKNOWN THEN THE FOLLOWING SHALL BE USED: $C_{wire} = 60\text{pF/ft.}$ (19pF/m.) $L_{wire} = .2\text{H/ft.}$ ($0.657\mu\text{H/m.}$) FOR EXAMPLE: $1000 \text{ ft} \times 60 \text{ pF/ft.} = 0.06\mu\text{F}$ $100 \text{ m} \times 197 \text{ pF/m.} = 0.0197\mu\text{F}$</p>		Voc(1)	Voc(1) <= Vmax	Isc(1)	Isc(1) <= Imax-Isc(2)	Ca(1)	Ca(1) >= Ci+Lwire(1)+Cwire(2)	Lo(1)	Lo(1) >= [Li+Lwire(1)+Lwire(2)]-Lo(2)	Voc(2)	Voc(2) <= Vmax	Isc(2)	Isc(2) <= Imax-Isc(1)	Ca(2)	Ca(2) >= Ci+Cwire(2)+Cwire(1)	Lo(2)	Lo(2) >= [Li+Lwire(2)+Lwire(1)]-Lo(1)	Pi	Vmax	Imax	Ci	Li	1W	7.93V	280mA	30.1μF	0μH
Voc(1)	Voc(1) <= Vmax																												
Isc(1)	Isc(1) <= Imax-Isc(2)																												
Ca(1)	Ca(1) >= Ci+Lwire(1)+Cwire(2)																												
Lo(1)	Lo(1) >= [Li+Lwire(1)+Lwire(2)]-Lo(2)																												
Voc(2)	Voc(2) <= Vmax																												
Isc(2)	Isc(2) <= Imax-Isc(1)																												
Ca(2)	Ca(2) >= Ci+Cwire(2)+Cwire(1)																												
Lo(2)	Lo(2) >= [Li+Lwire(2)+Lwire(1)]-Lo(1)																												
Pi	Vmax	Imax	Ci	Li																									
1W	7.93V	280mA	30.1μF	0μH																									
		<p>NOTE: MAXIMUM NUMBER OF PROBES AND CABLE LENGTH DEPENDS ON ENTITY PARAMETERS OF ASSOCIATED APPARATUS.</p> <p>DATA ZENER BARRIER PARAMETERS (2)</p> <table border="1"> <tr> <td>Pi</td> <td>Vmax</td> <td>Imax</td> <td>Ci</td> <td>Li</td> </tr> <tr> <td>1W</td> <td>7.93V</td> <td>280mA</td> <td>30.1μF</td> <td>0μH</td> </tr> </table> <p>PROBE ENTITY PARAMETERS</p> <table border="1"> <tr> <td>Pi</td> <td>Vmax</td> <td>Imax</td> <td>Ci</td> <td>Li</td> </tr> <tr> <td>1W</td> <td>7.93V</td> <td>280mA</td> <td>30.1μF</td> <td>0μH</td> </tr> </table> <p>THIRD ANGLE PROJECTION</p> <p>SURFACE FINISH</p> <p>UNLESS OTHERWISE SPECIFIED</p> <p>TOLERANCE ALLOWANCE</p> <p>UNLESS OTHERWISE SPECIFIED: +/-0.010 on 2 place decimals +/-0.005 on 3 place decimals +/-0.0005 on 4 place decimals +/-30 min. on all angles</p> <p>NOTES:</p> <p>COPRIGHT ©2005 AMETEK AUTOMATION & PROCESS TECHNOLOGIES. ALL RIGHTS RESERVED. DRAWING IS PROPERTY OF AMETEK AUTOMATION & PROCESS TECHNOLOGIES. UNAUTHORIZED USE, DUPLICATION OR DISTRIBUTION IS STRICTLY PROHIBITED BY FEDERAL LAW.</p> <p>AMETEK® AUTOMATION & PROCESS TECHNOLOGIES</p> <p>Clawson, MI 48017 U.S.A.</p> <p>DATE 12/12/13 SCALE DRAWING NO. REV. SIZE</p> <p>INSTALLATION DRAWING</p> <p>DR. KTP TITLE DATE 6/16/05 APP. GSL DRAWING NO. REV. SIZE</p> <p>I.S. VERSION</p> <p>HR DIGITAL STIK</p> <p>E0241200 C B</p>		Pi	Vmax	Imax	Ci	Li	1W	7.93V	280mA	30.1μF	0μH	Pi	Vmax	Imax	Ci	Li	1W	7.93V	280mA	30.1μF	0μH						
Pi	Vmax	Imax	Ci	Li																									
1W	7.93V	280mA	30.1μF	0μH																									
Pi	Vmax	Imax	Ci	Li																									
1W	7.93V	280mA	30.1μF	0μH																									

7250 Dimension Drawing





EC Declaration of Conformity

Manufacturer: AMETEK Automation & Process Technologies
6380 Brockway Road, Peck, MI 48466 USA

Identification of Equipment:
Series 7250 "HR Digital Stik" Liquid Level Sensor

Description of Device:

These devices are permanently mounted Intrinsically Safe Magnetostrictive based liquid level sensing transducers with temperature measurement capabilities. The level and temperature information is conveyed by an asynchronous serial digital output signal. Both the signal level and power supply voltage are typically +5Vdc. The devices can be specified with either PVDF or steel housing materials.

EC type certificate: FM Approvals Ltd. 1725 FM13ATEX0102X
FM Approvals Ltd. 1 Windsor Dials, Windsor, Berkshire, UK. SL4 1RS

Conformity Specifications: II 1 G Ex ia IIB T4 Ta : -40°C to +70°C

Council Directives:

Directive 94/9/EC, ATEX
Directive 89/336/EEC, EMC

Harmonized Standards:

EN60079-0:2012	Electrical apparatus for explosive gas atmospheres - Part 0: General requirements
EN60079-11:2012	Electrical apparatus for explosive gas atmospheres - Part 11: Intrinsic safety "i"
EN60079-26:2007	Electrical apparatus for explosive gas atmospheres – Part 26: Construction, test and marking of group II category I G electrical apparatus
EN61000-6-4:2001	Generic Standards – Emission Standard for Industrial Environments
EN55011:1998	Limits and methods of measurement of radio characteristics of industrial, scientific and medical (ISM) Radio Frequency equipment, Class B, Group 1
EN61326:2001	Electrical Equipment for measurement, control and laboratory use – EMC Requirements
EN61000-4-2:2000	Electrostatic Discharge Immunity
EN61000-4-3:2002	Radiated RF Immunity
EN61000-4-4:2001	Electrical Fast Transient Burst Immunity
EN61000-4-6:2001	Conducted Immunity
EN61000-4-8:2003	Magnetic Field Immunity


Signed:



Name: Glenn S. Loding
Position: Engineering Manager Dated: 12/2/13
Company: AMETEK Automation & Process Technologies



Other Products



Copyright 2012 by AMETEK AUTOMATION & PROCESS TECHNOLOGIES.
All Rights Reserved. Made in the USA.



1080 N. Crooks Road, Clawson, MI 48017-1097
Phone: 248-435-0700 Toll Free: 800-635-0289
Fax: 248-435-8120 www.ametekapt.com

7250.M10R
12/13.Z205